



WASHINGTON STATE
UNIVERSITY

Addendum No. 2
04/12/2024

**Stadium Way Roadways: Repave Stadium Way,
Wilson Road to Cougar Way**
Washington State University
Pullman, WA

Project No. 2087-2024
Washington State University
Facilities Services, Capital

Addendum No. 2
04/12/2024**Stadium Way Roadways: Repave Stadium Way, Wilson Road to Cougar Way**
Washington State University
Pullman, WA**Bid Date Now: 04/18/2024**

1. This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated March 20, 2024, and any prior addenda, as noted below.
2. Please acknowledge receipt of this addendum on the Form of Proposal.

This Addendum consists of three total pages including the following Attachments:

Sketch E 26 56 00 Type 02 - Pole Base Detail

Changes to prior Addenda:

None

Changes to Bidding Requirements:**1-1. SECTION 00 11 13 – Advertisement for Bids**

- Item 1. Replace “Bid Deadline: April 16, 2024, prior to 2:00 p.m., virtual bid opening at 2:30 p.m.”

Make read

*“Bid Deadline: **Thursday, April 18, 2024**, prior to 2:00 p.m., virtual bid opening at 2:30 p.m.”.*

Changes to Specifications:

None


Changes to Drawings:**DWG 1-1. Drawing C2.01 – Flag Lane Improvements Site Plan**

- Item 1. Delete Keyed Note #8.

Make read:

Reset luminaire on new foundation per WSU Standard Foundation Detail E 26 56 00 Type 2 attached.


END OF ADDENDUM No. 2



A

POLE BASE DETAIL

SCALE: 3/4" = 1'-0"



B

POLE BASE SECTION

NOTES

1. PRECAST CONCRETE POLE BASES ARE PREFERRED.
2. CONCRETE STRENGTH TO BE AT LEAST 4000 PSI.
3. CONCRETE FINISH F3 SMOOTH RUBBED ALL SURFACES ABOVE GRADE AND TO 6" BELOW GRADE.
4. PROVIDE 6" SPACE BETWEEN POLE BASE AND SIDEWALK.



Facilities Services
Pullman, Wa. 99164-3611
Main Office Ph 509-335-5571 Fax 509-335-6875

POLE BASE DETAIL

DETAIL NUMBER		TYPE
E 26 56 00		02
DATE: 04-25-2017	REVISION NO.: 0	1 OF 1