



WASHINGTON STATE
UNIVERSITY

Addendum No. 2
05/16/2024

EEME Install Additional DX Units in 106
Washington State University
Pullman, WA

Project No. 1970-2022
Washington State University
Facilities Services, Capital

**Addendum No. 2
05/16/2024**

**EEME Install Additional DX Units in 106
Washington State University
Pullman, WA**

Bid Date: May 21, 2024

1. This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated April 23, 2024, and any prior addenda, as noted below.
2. Please acknowledge receipt of this addendum on the Form of Proposal.

This Addendum consists of two total pages including the following Attachments:

N/A

Changes to prior Addenda, Specifications, Bidding Requirements, Drawings, and Substitution Requests:

None

Questions and Clarifications:

1. Contractor Question: Are there structural upgrades required prior to the landing of the new CU on the roof deck?
 - a. WSU Response: We do not expect any structural modifications to be needed to accommodate the new CU unit.

END OF ADDENDUM No. 2